

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**SECTORS 1 AND 2 SECONDARY LOOP****PUMPS LOCATED IN EAA EAST**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:SR02:SupTempAi	analog input	351	Deg. F.
G:PW:SR02:SetPtAi	analog input	352	Deg. F.
G:PW:SR02:DiffPresAi	analog input	353	PSIG
G:PW:SR02:DiffPresSetPtAi	analog input	354	PSIG
G:PW:SR02:SupFloAi	analog input	355	GPM
G:PW:SR02:RetFloAi	analog input	356	GPM
G:PW:SR02:ByPassValAi	analog input	358	%CLOS
G:PW:SREAA:SupTempAi	analog input	359	Deg. F.
G:PW:SREAA:SetPtAi	analog input	360	Deg. F.
G:PW:SREAA:DiffPresAi	analog input	361	PSIG
G:PW:SREAA:DiffPresSetPtAi	analog input	362	PSIG
G:PW:SREAA:SupFloAi	analog input	363	GPM
G:PW:SREAA:RetFloAi	analog input	364	GPM
G:PW:SREAA:MixValAi	analog input	365	%CLG
G:PW:SREAA:ByPassValAi	analog input	366	%CLOS
G:PW:SR02:Sec1/2-TempAi	analog input	380	Deg. F.
G:PW:SR02:EastEnableBi	binary input	1501	ENABLE/DISABLE
G:PW:SR02:HiFloEvBi	binary input	1502	ON/OFF
G:PW:SR02:StatusBi	binary input	1503	ON/OFF
G:PW:SR02:AlarmBi	binary input	1504	NORMAL/ALARM
G:PW:SR02:IsoValStatBi	binary input	1505	OPEN/CLOSED
G:PW:SR02:SuStbyValStatBi	binary input	1506	OPEN/CLOSED
G:PW:SR02:RtStbyValStatBi	binary input	1507	OPEN/CLOSED
G:PW:SREAA:EnableBi	binary input	1509	ENABLE/DISABLE
G:PW:SREAA:HiFloEvBi	binary input	1510	ON/OFF
G:PW:SREAA:StatusBi	binary input	1511	ON/OFF

Table 1:**APS\Net_Port\Bldg_400\Proc_Wtr\NP_R-E**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:SREAA:AlarmBi	binary input	1512	NORMAL/ALARM
G:PW:SREAA:IsoValStatBi	binary input	1513	OPEN/CLOSED
G:PW:SREAA:SuStbyValStatBi	binary input	1514	OPEN/CLOSED
G:PW:SREAA:RtStbyValStatBi	binary input	1515	OPEN/CLOSED
G:PW:SR02B:StatusBi	binary input	1524	ON/OFF

Table 1: **APS\Net_Port\Bldg_400\Proc_Wtr\NP_R-E**

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**SECTORS 3 AND 4 SECONDARY LOOP****PUMPS LOCATED IN BLDG. 400 MEZZANINE AT COLUMN 66**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:SR04:SupTempAi	analog input	411	Deg. F.
G:PW:SR04:DiffPresAi	analog input	413	PSIG
G:PW:SR04:DiffPresSetPtAi	analog input	414	PSIG
G:PW:SR04:SupFloAi	analog input	415	GPM
G:PW:SR04:RetFloAi	analog input	416	GPM
G:PW:SR04:ByPassValAi	analog input	418	% CLOS
G:PW:SR04:Sec3/4-TempAi	analog input	419	Deg. F.
G:PW:SR04:Seg1-EnableBi	binary input	1611	ENABLE/DISABLE
G:PW:SR04:HiFloEvBi	binary input	1612	ON/OFF
G:PW:SR04:StatusBi	binary input	1613	ON/OFF
G:PW:SR04:AlarmBi	binary input	1614	NORMAL/ALARM
G:PW:SR04B:StatusBi	binary input	1615	ON/OFF
G:PW:SR04B:AlarmBi	binary input	1616	NORMAL/ALARM
G:PW:SR04:IsoValStatBi	binary input	1617	OPEN/CLOSED
G:PW:SR04:IsoValAlarm	binary input	1618	NORMAL/ALARM

Table 2:**APS\Net_Port\Bldg_400\Proc_Wtr\NP_Seg1**

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**SECTORS 5 AND 6 SECONDARY LOOP****PUMPS LOCATED IN BLDG. 400 MEZZNINE AT COLUMN 72**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:SR06:SupTempAi	analog input	421	Deg. F.
G:PW:SR06:DiffPresAi	analog input	423	PSIG
G:PW:SR06:DiffPresSetPtAi	analog input	424	PSIG
G:PW:SR06:SupFloAi	analog input	425	GPM
G:PW:SR06:RetFloAi	analog input	426	GPM
G:PW:SR06:ByPassValAi	analog input	428	% CLOS
G:PW:SR06:Sec5/6-TempAi	analog input	429	Deg. F.
G:PW:SR06:Seg2-EnableBi	binary input	1621	ENABLE/DISABLE
G:PW:SR06:HiFloEvBi	binary input	1622	ON/OFF
G:PW:SR06:StatusBi	binary input	1623	ON/OFF
G:PW:SR06:AlarmBi	binary input	1624	NORMAL/ALARM
G:PW:SR06B:StatusBi	binary input	1625	ON/OFF
G:PW:SR06B:AlarmBi	binary input	1626	NORMAL/ALARM
G:PW:SR06:IsoValStatBi	binary input	1627	OPEN/CLOSED
G:PW:SR06:IsoValAlarm	binary input	1628	NORMAL/ALARM

Table 3:**APS\Net_Port\Bldg_400\Proc_Wtr\NP_Seg2**

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**SECTORS 7 AND 8 SECONDARY LOOP****PUMPS LOCATED IN BLDG. 400 MEZZNINE AT COLUMN 78**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:SR08:SupTempAi	analog input	431	Deg. F.
G:PW:SR08:DiffPresAi	analog input	433	PSIG
G:PW:SR08:DiffPresSetPtAi	analog input	434	PSIG
G:PW:SR08:SupFloAi	analog input	435	GPM
G:PW:SR08:RetFloAi	analog input	436	GPM
G:PW:SR08:ByPassValAi	analog input	438	% CLOS
G:PW:SR08:Sec7/8-TempAi	analog input	439	Deg. F.
G:PW:SR08:Seg3-EnableBi	binary input	1631	ENABLE/DISABLE
G:PW:SR08:HiFloEvBi	binary input	1632	ON/OFF
G:PW:SR08:StatusBi	binary input	1633	ON/OFF
G:PW:SR08:AlarmBi	binary input	1634	NORMAL/ALARM
G:PW:SR08B:StatusBi	binary input	1635	ON/OFF
G:PW:SR08B:AlarmBi	binary input	1636	NORMAL/ALARM
G:PW:SR08:IsoValStatBi	binary input	1637	OPEN/CLOSED
G:PW:SR08:IsoValAlarm	binary input	1638	NORMAL/ALARM

Table 4:**APS\Net_Port\Bldg_400\Proc_Wtr\NP_Seg3**

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**SECTORS 9 AND 10 SECONDARY LOOP****PUMPS LOCATED IN BLDG. 400 MEZZNINE AT COLUMN 84**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:SR10:SupTempAi	analog input	441	Deg. F.
G:PW:SR10:DiffPresAi	analog input	443	PSIG
G:PW:SR10:DiffPresSetPtAi	analog input	444	PSIG
G:PW:SR10:SupFloAi	analog input	445	GPM
G:PW:SR10:RetFloAi	analog input	446	GPM
G:PW:SR10:ByPassValAi	analog input	448	% CLOS
G:PW:SR10:Sec9/10-TempAi	analog input	449	Deg. F.
G:PW:SR10:Seg4-EnableBi	binary input	1641	ENABLE/DISABLE
G:PW:SR10:HiFloEvBi	binary input	1642	ON/OFF
G:PW:SR10:StatusBi	binary input	1643	ON/OFF
G:PW:SR10:AlarmBi	binary input	1644	NORMAL/ALARM
G:PW:SR10B:StatusBi	binary input	1645	ON/OFF
G:PW:SR10B:AlarmBi	binary input	1646	NORMAL/ALARM
G:PW:SR10:IsoValStatBi	binary input	1647	OPEN/CLOSED
G:PW:SR10:IsoValAlarm	binary input	1648	NORMAL/ALARM

Table 5:**APS\Net_Port\Bldg_400\Proc_Wtr\NP_Seg4**

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**SECTORS 11 AND 12 SECONDARY LOOP****PUMPS LOCATED IN BLDG. 400 MEZZNINE AT COLUMN 90**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:SR12:SupTempAi	analog input	451	Deg. F.
G:PW:SR12:DiffPresAi	analog input	453	PSIG
G:PW:SR12:DiffPresSetPtAi	analog input	454	PSIG
G:PW:SR12:SupFloAi	analog input	455	GPM
G:PW:SR12:RetFloAi	analog input	456	GPM
G:PW:SR12:MixValAi	analog input	457	% CLG
G:PW:SR12:ByPassValAi	analog input	458	% CLOS
G:PW:SR12:Sec11/12-TempAi	analog input	459	Deg. F.
G:PW:SR12:Seg5-EnableBi	binary input	1651	ENABLE/DISABLE
G:PW:SR12:HiFloEvBi	binary input	1652	ON/OFF
G:PW:SR12:StatusBi	binary input	1653	ON/OFF
G:PW:SR12:AlarmBi	binary input	1654	NORMAL/ALARM
G:PW:SR12B:StatusBi	binary input	1655	ON/OFF
G:PW:SR12B:AlarmBi	binary input	1656	NORMAL/ALARM
G:PW:SR12:IsoValStatBi	binary input	1657	OPEN/CLOSED
G:PW:SR12:IsoValAlarm	binary input	1658	NORMAL/ALARM

Table 6:**APS\Net_Port\Bldg_400\Proc_Wtr\NP_Seg5**

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**SECTORS 13 AND 14 SECONDARY LOOP****PUMPS LOCATED IN BLDG. 400 MEZZNINE AT COLUMN 96**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:SR14:SupTempAi	analog input	461	Deg. F.
G:PW:SR14:DiffPresAi	analog input	463	PSIG
G:PW:SR14:DiffPresSetPtAi	analog input	464	PSIG
G:PW:SR14:SupFloAi	analog input	465	GPM
G:PW:SR14:RetFloAi	analog input	466	GPM
G:PW:SR14:ByPassValAi	analog input	468	% CLOS
G:PW:SR14:Sec13/14-TempAi	analog input	469	Deg. F.
G:PW:SR14:Seg6-EnableBi	binary input	1661	ENABLE/DISABLE
G:PW:SR14:HiFloEvBi	binary input	1662	ON/OFF
G:PW:SR14:StatusBi	binary input	1663	ON/OFF
G:PW:SR14:AlarmBi	binary input	1664	NORMAL/ALARM
G:PW:SR14B:StatusBi	binary input	1665	ON/OFF
G:PW:SR14B:AlarmBi	binary input	1666	NORMAL/ALARM
G:PW:SR14:IsoValStatBi	binary input	1667	OPEN/CLOSED
G:PW:SR14:IsoValAlarm	binary input	1668	NORMAL/ALARM

Table 7: **APS\Net_Port\Bldg_400\Proc_Wtr\NP_Seg6**

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**SECTORS 15 AND 16 SECONDARY LOOP****PUMPS LOCATED IN BLDG. 400 MEZZNINE AT COLUMN 102**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:SR16:SupTempAi	analog input	471	Deg. F.
G:PW:SR16:DiffPresAi	analog input	473	PSIG
G:PW:SR16:DiffPresSetPtAi	analog input	474	PSIG
G:PW:SR16:SupFloAi	analog input	475	GPM
G:PW:SR16:RetFloAi	analog input	476	GPM
G:PW:SR16:ByPassValAi	analog input	478	% CLOS
G:PW:SR16:Sec15/16-TempAi	analog input	479	Deg. F.
G:PW:SR16:Seg7-EnableBi	binary input	1671	ENABLE/DISABLE
G:PW:SR16:HiFloEvBi	binary input	1672	ON/OFF
G:PW:SR16:StatusBi	binary input	1673	ON/OFF
G:PW:SR16:AlarmBi	binary input	1674	NORMAL/ALARM
G:PW:SR16B:StatusBi	binary input	1675	ON/OFF
G:PW:SR16B:AlarmBi	binary input	1676	NORMAL/ALARM
G:PW:SR16:IsoValStatBi	binary input	1677	OPEN/CLOSED
G:PW:SR16:IsoValAlarm	binary input	1678	NORMAL/ALARM

Table 8: **APS\Net_Port\Bldg_400\Proc_Wtr\NP_Seg7**

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**SECTORS 17 AND 18 SECONDARY LOOP****PUMPS LOCATED IN BLDG. 400 MEZZNINE AT COLUMN 108**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:SR18:SupTempAi	analog input	481	Deg. F.
G:PW:SR18:DiffPresAi	analog input	483	PSIG
G:PW:SR18:DiffPresSetPtAi	analog input	484	PSIG
G:PW:SR18:SupFloAi	analog input	485	GPM
G:PW:SR18:RetFloAi	analog input	486	GPM
G:PW:SR18:ByPassValAi	analog input	488	% CLOS
G:PW:SR18:Sec17/18-TempAi	analog input	489	Deg. F.
G:PW:SR18:Seg8-EnableBi	binary input	1681	ENABLE/DISABLE
G:PW:SR18:HiFloEvBi	binary input	1682	ON/OFF
G:PW:SR18:StatusBi	binary input	1683	ON/OFF
G:PW:SR18:AlarmBi	binary input	1684	NORMAL/ALARM
G:PW:SR18B:StatusBi	binary input	1685	ON/OFF
G:PW:SR18B:AlarmBi	binary input	1686	NORMAL/ALARM
G:PW:SR18:IsoValStatBi	binary input	1687	OPEN/CLOSED
G:PW:SR18:IsoValAlarm	binary input	1688	NORMAL/ALARM

Table 9: **APS\Net_Port\Bldg_400\Proc_Wtr\NP_Seg8**

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**SECTORS 19 AND 20 SECONDARY LOOP****PUMPS LOCATED IN BLDG. 400 MEZZNINE AT COLUMN 114**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:SR20:SupTempAi	analog input	491	Deg. F.
G:PW:SR20:DiffPresAi	analog input	493	PSIG
G:PW:SR20:DiffPresSetPtAi	analog input	494	PSIG
G:PW:SR20:SupFloAi	analog input	495	GPM
G:PW:SR20:RetFloAi	analog input	496	GPM
G:PW:SR20:ByPassValAi	analog input	498	% CLOS
G:PW:SR20:Sec19/20-TempAi	analog input	499	Deg. F.
G:PW:SR20:Seg9-EnableBi	binary input	1691	ENABLE/DISABLE
G:PW:SR20:HiFloEvBi	binary input	1692	ON/OFF
G:PW:SR20:StatusBi	binary input	1693	ON/OFF
G:PW:SR20:AlarmBi	binary input	1694	NORMAL/ALARM
G:PW:SR20B:StatusBi	binary input	1695	ON/OFF
G:PW:SR20B:AlarmBi	binary input	1696	NORMAL/ALARM
G:PW:SR20:IsoValStatBi	binary input	1697	OPEN/CLOSED
G:PW:SR20:IsoValAlarm	binary input	1698	NORMAL/ALARM

Table 10: **APS\Net_Port\Bldg_400\Proc_Wtr\NP_Seg9**

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**SECTORS 21 AND 22 SECONDARY LOOP****PUMPS LOCATED IN BLDG. 400 MEZZNINE AT COLUMN 120**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:SR22:SupTempAi	analog input	501	Deg. F.
G:PW:SR22:DiffPresAi	analog input	503	PSIG
G:PW:SR22:DiffPresSetPtAi	analog input	504	PSIG
G:PW:SR22:SupFloAi	analog input	505	GPM
G:PW:SR22:RetFloAi	analog input	506	GPM
G:PW:SR22:ByPassValAi	analog input	508	% CLOS
G:PW:SR22:Sec21/22-TempAi	analog input	509	Deg. F.
G:PW:SR22:Seg10-EnableBi	binary input	1701	ENABLE/DISABLE
G:PW:SR22:HiFloEvBi	binary input	1702	ON/OFF
G:PW:SR22:StatusBi	binary input	1703	ON/OFF
G:PW:SR22:AlarmBi	binary input	1704	NORMAL/ALARM
G:PW:SR22B:StatusBi	binary input	1705	ON/OFF
G:PW:SR22B:AlarmBi	binary input	1706	NORMAL/ALARM
G:PW:SR22:IsoValStatBi	binary input	1707	OPEN/CLOSED
G:PW:SR22:IsoValAlarm	binary input	1708	NORMAL/ALARM

Table 11:**APS\Net_Port\Bldg_400\Proc_Wtr\NP_Seg10**

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**SECTORS 23 AND 24 SECONDARY LOOP****PUMPS LOCATED IN BLDG. 400 MEZZNINE AT COLUMN 126**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:SR24:SupTempAi	analog input	511	Deg. F.
G:PW:SR24:DiffPresAi	analog input	513	PSIG
G:PW:SR24:DiffPresSetPtAi	analog input	514	PSIG
G:PW:SR24:SupFloAi	analog input	515	GPM
G:PW:SR24:RetFloAi	analog input	516	GPM
G:PW:SR24:ByPassValAi	analog input	518	% CLOS
G:PW:SR24:Sec23/24-TempAi	analog input	519	Deg. F.
G:PW:SR24:Seg11-EnableBi	binary input	1711	ENABLE/DISABLE
G:PW:SR24:HiFloEvBi	binary input	1712	ON/OFF
G:PW:SR24:StatusBi	binary input	1713	ON/OFF
G:PW:SR24:AlarmBi	binary input	1714	NORMAL/ALARM
G:PW:SR24B:StatusBi	binary input	1715	ON/OFF
G:PW:SR24B:AlarmBi	binary input	1716	NORMAL/ALARM
G:PW:SR24:IsoValStatBi	binary input	1717	OPEN/CLOSED
G:PW:SR24:IsoValAlarm	binary input	1718	NORMAL/ALARM

Table 12:**APS\Net_Port\Bldg_400\Proc_Wtr\NP_Seg11**

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**SECTORS 25 AND 26 SECONDARY LOOP****PUMPS LOCATED IN BLDG. 400 MEZZNINE AT COLUMN 132**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:SR26:SupTempAi	analog input	521	Deg. F.
G:PW:SR26:DiffPresAi	analog input	523	PSIG
G:PW:SR26:DiffPresSetPtAi	analog input	524	PSIG
G:PW:SR26:SupFloAi	analog input	525	GPM
G:PW:SR26:RetFloAi	analog input	526	GPM
G:PW:SR26:ByPassValAi	analog input	528	% CLOS
G:PW:SR26:Sec25/26-TempAi	analog input	529	Deg. F.
G:PW:SR26:Seg12-EnableBi	binary input	1721	ENABLE/DISABLE
G:PW:SR26:HiFloEvBi	binary input	1722	ON/OFF
G:PW:SR26:StatusBi	binary input	1723	ON/OFF
G:PW:SR26:AlarmBi	binary input	1724	NORMAL/ALARM
G:PW:SR26B:StatusBi	binary input	1725	ON/OFF
G:PW:SR26B:AlarmBi	binary input	1726	NORMAL/ALARM
G:PW:SR26:IsoValStatBi	binary input	1727	OPEN/CLOSED
G:PW:SR26:IsoValAlarm	binary input	1728	NORMAL/ALARM

Table 13:**APS\Net_Port\Bldg_400\Proc_Wtr\NP_Seg12**

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**SECTORS 27 AND 28 SECONDARY LOOP****PUMPS LOCATED IN BLDG. 400 MEZZNINE AT COLUMN 138**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:SR28:SupTempAi	analog input	531	Deg. F.
G:PW:SR28:DiffPresAi	analog input	533	PSIG
G:PW:SR28:DiffPresSetPtAi	analog input	534	PSIG
G:PW:SR28:SupFloAi	analog input	535	GPM
G:PW:SR28:RetFloAi	analog input	536	GPM
G:PW:SR28:ByPassValAi	analog input	538	% CLOS
G:PW:SR28:Sec27/28-TempAi	analog input	539	Deg. F.
G:PW:SR28:Seg13-EnableBi	binary input	1731	ENABLE/DISABLE
G:PW:SR28:HiFloEvBi	binary input	1732	ON/OFF
G:PW:SR28:StatusBi	binary input	1733	ON/OFF
G:PW:SR28:AlarmBi	binary input	1734	NORMAL/ALARM
G:PW:SR28B:StatusBi	binary input	1735	ON/OFF
G:PW:SR28B:AlarmBi	binary input	1736	NORMAL/ALARM
G:PW:SR28:IsoValStatBi	binary input	1737	OPEN/CLOSED
G:PW:SR28:IsoValAlarm	binary input	1738	NORMAL/ALARM

Table 14:**APS\Net_Port\Bldg_400\Proc_Wtr\NP_Seg13**

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**SECTORS 29 AND 30 SECONDARY LOOP****PUMPS LOCATED IN BLDG. 400 MEZZNINE AT COLUMN 144**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:SR30:SupTempAi	analog input	541	Deg. F.
G:PW:SR30:DiffPresAi	analog input	543	PSIG
G:PW:SR30:DiffPresSetPtAi	analog input	544	PSIG
G:PW:SR30:SupFloAi	analog input	545	GPM
G:PW:SR30:RetFloAi	analog input	546	GPM
G:PW:SR30:ByPassValAi	analog input	548	% CLOS
G:PW:SR30:Sec29/30-TempAi	analog input	549	Deg. F.
G:PW:SR30:Seg14-EnableBi	binary input	1741	ENABLE/DISABLE
G:PW:SR30:HiFloEvBi	binary input	1742	ON/OFF
G:PW:SR30:StatusBi	binary input	1743	ON/OFF
G:PW:SR30:AlarmBi	binary input	1744	NORMAL/ALARM
G:PW:SR30B:StatusBi	binary input	1745	ON/OFF
G:PW:SR30B:AlarmBi	binary input	1746	NORMAL/ALARM
G:PW:SR30:IsoValStatBi	binary input	1747	OPEN/CLOSED
G:PW:SR30:IsoValAlarm	binary input	1748	NORMAL/ALARM

Table 15:**APS\Net_Port\Bldg_400\Proc_Wtr\NP_Seg14**

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**SECTORS 31 AND 32 SECONDARY LOOP****PUMPS LOCATED IN BLDG. 400 MEZZNINE AT COLUMN 150**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:SR32:SupTempAi	analog input	551	Deg. F.
G:PW:SR32:DiffPresAi	analog input	553	PSIG
G:PW:SR32:DiffPresSetPtAi	analog input	554	PSIG
G:PW:SR32:SupFloAi	analog input	555	GPM
G:PW:SR32:RetFloAi	analog input	556	GPM
G:PW:SR32:ByPassValAi	analog input	558	% CLOS
G:PW:SR32:Sec31/32-TempAi	analog input	559	Deg. F.
G:PW:SR32:Seg15-EnableBi	binary input	1751	ENABLE/DISABLE
G:PW:SR32:HiFloEvBi	binary input	1752	ON/OFF
G:PW:SR32:StatusBi	binary input	1753	ON/OFF
G:PW:SR32:AlarmBi	binary input	1754	NORMAL/ALARM
G:PW:SR32B:StatusBi	binary input	1755	ON/OFF
G:PW:SR32B:AlarmBi	binary input	1756	NORMAL/ALARM
G:PW:SR32:IsoValStatBi	binary input	1757	OPEN/CLOSED
G:PW:SR32:IsoValAlarm	binary input	1758	NORMAL/ALARM

Table 16:**APS\Net_Port\Bldg_400\Proc_Wtr\NP_Seg15**

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**SECTORS 33 AND 34 SECONDARY LOOP****PUMPS LOCATED IN BLDG. 400 MEZZNINE AT COLUMN 156**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:SR34:SupTempAi	analog input	561	Deg. F.
G:PW:SR34:DiffPresAi	analog input	563	PSIG
G:PW:SR34:DiffPresSetPtAi	analog input	564	PSIG
G:PW:SR34:SupFloAi	analog input	565	GPM
G:PW:SR34:RetFloAi	analog input	566	GPM
G:PW:SR34:ByPassValAi	analog input	568	% CLOS
G:PW:SR34:Sec33/34-TempAi	analog input	569	Deg. F.
G:PW:SR34:Seg16-EnableBi	binary input	1761	ENABLE/DISABLE
G:PW:SR34:HiFloEvBi	binary input	1762	ON/OFF
G:PW:SR34:StatusBi	binary input	1763	ON/OFF
G:PW:SR34:AlarmBi	binary input	1764	NORMAL/ALARM
G:PW:SR34B:StatusBi	binary input	1765	ON/OFF
G:PW:SR34B:AlarmBi	binary input	1766	NORMAL/ALARM
G:PW:SR34:IsoValStatBi	binary input	1767	OPEN/CLOSED
G:PW:SR34:IsoValAlarm	binary input	1768	NORMAL/ALARM

Table 17:**APS\Net_Port\Bldg_400\Proc_Wtr\NP_Seg16**

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**SECTORS 35 AND 36 SECONDARY LOOP****PUMPS LOCATED IN BLDG. 400 MEZZNINE AT COLUMN 162**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:SR36:SupTempAi	analog input	571	Deg. F.
G:PW:SR36:DiffPresAi	analog input	573	PSIG
G:PW:SR36:DiffPresSetPtAi	analog input	574	PSIG
G:PW:SR36:SupFloAi	analog input	575	GPM
G:PW:SR36:RetFloAi	analog input	576	GPM
G:PW:SR36:ByPassValAi	analog input	578	% CLOS
G:PW:SR36:Sec35/36-TempAi	analog input	579	Deg. F.
G:PW:SR36:Seg17-EnableBi	binary input	1771	ENABLE/DISABLE
G:PW:SR36:HiFloEvBi	binary input	1772	ON/OFF
G:PW:SR36:StatusBi	binary input	1773	ON/OFF
G:PW:SR36:AlarmBi	binary input	1774	NORMAL/ALARM
G:PW:SR36B:StatusBi	binary input	1775	ON/OFF
G:PW:SR36B:AlarmBi	binary input	1776	NORMAL/ALARM
G:PW:SR36:IsoValStatBi	binary input	1777	OPEN/CLOSED
G:PW:SR36:IsoValAlarm	binary input	1778	NORMAL/ALARM

Table 18:**APS\Net_Port\Bldg_400\Proc_Wtr\NP_Seg17**

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**SECTORS 37 AND 38 SECONDARY LOOP****PUMPS LOCATED IN BLDG. 400 MEZZNINE AT COLUMN 168**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:SR38:SupTempAi	analog input	581	Deg. F.
G:PW:SR38:DiffPresAi	analog input	583	PSIG
G:PW:SR38:DiffPresSetPtAi	analog input	584	PSIG
G:PW:SR38:SupFloAi	analog input	585	GPM
G:PW:SR38:RetFloAi	analog input	586	GPM
G:PW:SR38:ByPassValAi	analog input	588	% CLOS
G:PW:SR38:Sec37/38-TempAi	analog input	589	Deg. F.
G:PW:SR38:Seg18-EnableBi	binary input	1781	ENABLE/DISABLE
G:PW:SR38:HiFloEvBi	binary input	1782	ON/OFF
G:PW:SR38:StatusBi	binary input	1783	ON/OFF
G:PW:SR38:AlarmBi	binary input	1784	NORMAL/ALARM
G:PW:SR38B:StatusBi	binary input	1785	ON/OFF
G:PW:SR38B:AlarmBi	binary input	1786	NORMAL/ALARM
G:PW:SR38:IsoValStatBi	binary input	1787	OPEN/CLOSED
G:PW:SR38:IsoValAlarm	binary input	1788	NORMAL/ALARM

Table 19: APS\Net_Port\Bldg_400\Proc_Wtr\NP_Seg18

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**SECTORS 39 AND 40 SECONDARY LOOP****PUMPS LOCATED IN BLDG. 400 MEZZNINE AT EAA MEZZANINE WEST**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:SR40:SupTempAi	analog input	367	Deg. F.
G:PW:SR40:DiffPresAi	analog input	369	PSIG
G:PW:SR40:DiffPresSetPtAi	analog input	370	PSIG
G:PW:SR40:SupFloAi	analog input	371	GPM
G:PW:SR40:RetFloAi	analog input	372	GPM
G:PW:SR40:ByPassValAi	analog input	374	% CLOS
G:PW:SR40:Sec39/40-TempAi	analog input	379	Deg. F.
G:PW:SR40:West-EnableBi	binary input	1517	ENABLE/DISABLE
G:PW:SR40:HiFloEvBi	binary input	1518	ON/OFF
G:PW:SR40:StatusBi	binary input	1519	ON/OFF
G:PW:SR40B:StatusBi	binary input	1520	ON/OFF
G:PW:SR40:AlarmBi	binary input	1521	NORMAL/ALARM
G:PW:SR40:IsoValStatBi	binary input	1522	OPEN/CLOSED

Table 20:**APS\Net_Port\Bldg_400\Proc_Wtr\NP_R-W**

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**VACUUM CHAMBER COOLING SYSTEM****SECTORS 1 AND 2 LOCATED IN EAA MEZZANINE EAST WING****Table 21:** **APS\Net_Port\Bldg_400\Proc_Wtr\NPSRVC-E**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:VC02:SupTempAi	analog input	375	Deg. F.
G:PW:VC02:EnableBi	binary input	1525	ENABLE/DISABLE
G:PW:VC02:PumpStatBi	binary input	1526	ON/OFF
G:PW:VC02B:PumpStatBi	binary input	1527	ON/OFF
G:PW:VC02:LoLoAlarmBi	binary input	1528	NORMAL/ALARM
G:PW:VC02:LoLvAlarmBi	binary input	1529	NORMAL/ALARM
G:PW:VC02:FloSwStatBi	binary input	1530	FLOW/NOFLOW

SECTORS 39 AND 40 LOCATED IN EAA MEZZANINE WEST WING**Table 22:** **APS\Net_Port\Bldg_400\Proc_Wtr\NPSRVC-W**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:VC40:SupTempAi	analog input	377	Deg. F.
G:PW:VC40:EnableBi	binary input	1531	ENABLE/DISABLE
G:PW:VC40:PumpStatBi	binary input	1532	ON/OFF
G:PW:VC40B:PumpStatBi	binary input	1533	ON/OFF
G:PW:VC40:LoLoAlarmBi	binary input	1534	NORMAL/ALARM
G:PW:VC40:LoLvAlarmBi	binary input	1535	NORMAL/ALARM
G:PW:VC40:FloSwStatBi	binary input	1536	FLOW/NOFLOW

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**VACUUM CHAMBER COOLING SYSTEM****SECTORS 3 AND 4 LOCATED IN BLDG. 400 MEZZANINE COLUMN 66****Table 23: APS\Net_Port\Bldg_400\Proc_Wtr\NPSRVC1**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:VC04:SupTempAi	analog input	601	Deg. F.
G:PW:VC04:EnableBi	binary input	1801	ENABLE/DISABLE
G:PW:VC04:PumpStatBi	binary input	1802	ON/OFF
G:PW:VC04B:PumpStatBi	binary input	1803	ON/OFF
G:PW:VC04:LoLoAlarmBi	binary input	1804	NORMAL/ALARM
G:PW:VC04:LoLvAlarmBi	binary input	1805	NORMAL/ALARM
G:PW:VC04:FloSwStatBi	binary input	1806	FLOW/NOFLOW

SECTORS 5 AND 6 LOCATED IN BLDG. 400 MEZZANINE COLUMN 72**Table 24: APS\Net_Port\Bldg_400\Proc_Wtr\NPSRVC2**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:VC06:SupTempAi	analog input	603	Deg. F.
G:PW:VC06:EnableBi	binary input	1807	ENABLE/DISABLE
G:PW:VC06:PumpStatBi	binary input	1808	ON/OFF
G:PW:VC06B:PumpStatBi	binary input	1809	ON/OFF
G:PW:VC06:LoLoAlarmBi	binary input	1810	NORMAL/ALARM
G:PW:VC06:LoLvAlarmBi	binary input	1811	NORMAL/ALARM
G:PW:VC06:FloSwStatBi	binary input	1812	FLOW/NOFLOW

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**VACUUM CHAMBER COOLING SYSTEM****SECTORS 7 AND 8 LOCATED IN BLDG. 400 MEZZANINE COLUMN 78****Table 25: APS\Net_Port\Bldg_400\Proc_Wtr\NPSRVC3**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:VC08:SupTempAi	analog input	605	Deg. F.
G:PW:VC08:EnableBi	binary input	1813	ENABLE/DISABLE
G:PW:VC08:PumpStatBi	binary input	1814	ON/OFF
G:PW:VC08B:PumpStatBi	binary input	1815	ON/OFF
G:PW:VC08:LoLoAlarmBi	binary input	1816	NORMAL/ALARM
G:PW:VC08:LoLvAlarmBi	binary input	1817	NORMAL/ALARM
G:PW:VC08:FloSwStatBi	binary input	1818	FLOW/NOFLOW

SECTORS 9 AND 10 LOCATED IN BLDG. 400 MEZZANINE COLUMN 84**Table 26: APS\Net_Port\Bldg_400\Proc_Wtr\NPSRVC4**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:VC10:SupTempAi	analog input	607	Deg. F.
G:PW:VC10:EnableBi	binary input	1819	ENABLE/DISABLE
G:PW:VC10:PumpStatBi	binary input	1820	ON/OFF
G:PW:VC10B:PumpStatBi	binary input	1821	ON/OFF
G:PW:VC10:LoLoAlarmBi	binary input	1822	NORMAL/ALARM
G:PW:VC10:LoLvAlarmBi	binary input	1823	NORMAL/ALARM
G:PW:VC10:FloSwStatBi	binary input	1824	FLOW/NOFLOW

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**VACUUM CHAMBER COOLING SYSTEM****SECTORS 11 AND 12 LOCATED IN BLDG. 400 MEZZANINE COLUMN 90****Table 27: APS\Net_Port\Bldg_400\Proc_Wtr\NPSRVC5**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:VC12:SupTempAi	analog input	609	Deg. F.
G:PW:VC12:EnableBi	binary input	1825	ENABLE/DISABLE
G:PW:VC12:PumpStatBi	binary input	1826	ON/OFF
G:PW:VC12B:PumpStatBi	binary input	1827	ON/OFF
G:PW:VC12:LoLoAlarmBi	binary input	1828	NORMAL/ALARM
G:PW:VC12:LoLvAlarmBi	binary input	1829	NORMAL/ALARM
G:PW:VC12:FloSwStatBi	binary input	1830	FLOW/NOFLOW

SECTORS 13 AND 14 LOCATED IN BLDG. 400 MEZZANINE COLUMN 96**Table 28: APS\Net_Port\Bldg_400\Proc_Wtr\NPSRVC6**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:VC14:SupTempAi	analog input	611	Deg. F.
G:PW:VC14:EnableBi	binary input	1831	ENABLE/DISABLE
G:PW:VC14:PumpStatBi	binary input	1832	ON/OFF
G:PW:VC14B:PumpStatBi	binary input	1833	ON/OFF
G:PW:VC14:LoLoAlarmBi	binary input	1834	NORMAL/ALARM
G:PW:VC14:LoLvAlarmBi	binary input	1835	NORMAL/ALARM
G:PW:VC14:FloSwStatBi	binary input	1836	FLOW/NOFLOW

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)

VACUUM CHAMBER COOLING SYSTEM

SECTORS 15 AND 16 LOCATED IN BLDG. 400 MEZZANINE COLUMN 102

Table 29: APS\Net_Port\Bldg_400\Proc_Wtr\NPSRVC7

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:VC16:SupTempAi	analog input	613	Deg. F.
G:PW:VC16:EnableBi	binary input	1837	ENABLE/DISABLE
G:PW:VC16:PumpStatBi	binary input	1838	ON/OFF
G:PW:VC16B:PumpStatBi	binary input	1839	ON/OFF
G:PW:VC16:LoLoAlarmBi	binary input	1840	NORMAL/ALARM
G:PW:VC16:LoLvAlarmBi	binary input	1841	NORMAL/ALARM
G:PW:VC16:FloSwStatBi	binary input	1842	FLOW/NOFLOW

SECTORS 17 AND 18 LOCATED IN BLDG. 400 MEZZANINE COLUMN 108

Table 30: APS\Net_Port\Bldg_400\Proc_Wtr\NPSRVC8

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:VC18:SupTempAi	analog input	615	Deg. F.
G:PW:VC18:EnableBi	binary input	1843	ENABLE/DISABLE
G:PW:VC18:PumpStatBi	binary input	1844	ON/OFF
G:PW:VC18B:PumpStatBi	binary input	1845	ON/OFF
G:PW:VC18:LoLoAlarmBi	binary input	1846	NORMAL/ALARM
G:PW:VC18:LoLvAlarmBi	binary input	1847	NORMAL/ALARM
G:PW:VC18:FloSwStatBi	binary input	1848	FLOW/NOFLOW

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**VACUUM CHAMBER COOLING SYSTEM****SECTORS 19 AND 20 LOCATED IN BLDG. 400 MEZZANINE COLUMN 114****Table 31: APS\Net_Port\Bldg_400\Proc_Wtr\NPSRVC9**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:VC20:SupTempAi	analog input	617	Deg. F.
G:PW:VC20:EnableBi	binary input	1849	ENABLE/DISABLE
G:PW:VC20:PumpStatBi	binary input	1850	ON/OFF
G:PW:VC20B:PumpStatBi	binary input	1851	ON/OFF
G:PW:VC20:LoLoAlarmBi	binary input	1852	NORMAL/ALARM
G:PW:VC20:LoLvAlarmBi	binary input	1853	NORMAL/ALARM
G:PW:VC20:FloSwStatBi	binary input	1854	FLOW/NOFLOW

SECTORS 21 AND 22 LOCATED IN BLDG. 400 MEZZANINE COLUMN 120**Table 32: APS\Net_Port\Bldg_400\Proc_Wtr\NPSRVC10**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:VC22:SupTempAi	analog input	619	Deg. F.
G:PW:VC22:EnableBi	binary input	1855	ENABLE/DISABLE
G:PW:VC22:PumpStatBi	binary input	1856	ON/OFF
G:PW:VC22B:PumpStatBi	binary input	1857	ON/OFF
G:PW:VC22:LoLoAlarmBi	binary input	1858	NORMAL/ALARM
G:PW:VC22:LoLvAlarmBi	binary input	1859	NORMAL/ALARM
G:PW:VC22:FloSwStatBi	binary input	1860	FLOW/NOFLOW

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**VACUUM CHAMBER COOLING SYSTEM****SECTORS 23 AND 24 LOCATED IN BLDG. 400 MEZZANINE COLUMN 126****Table 33: APS\Net_Port\Bldg_400\Proc_Wtr\NPSRVC11**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:VC24:SupTempAi	analog input	621	Deg. F.
G:PW:VC24:EnableBi	binary input	1861	ENABLE/DISABLE
G:PW:VC24:PumpStatBi	binary input	1862	ON/OFF
G:PW:VC24B:PumpStatBi	binary input	1863	ON/OFF
G:PW:VC24:LoLoAlarmBi	binary input	1864	NORMAL/ALARM
G:PW:VC24:LoLvAlarmBi	binary input	1865	NORMAL/ALARM
G:PW:VC24:FloSwStatBi	binary input	1866	FLOW/NOFLOW

SECTORS 25 AND 26 LOCATED IN BLDG. 400 MEZZANINE COLUMN 132**Table 34: APS\Net_Port\Bldg_400\Proc_Wtr\NPSRVC12**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:VC26:SupTempAi	analog input	623	Deg. F.
G:PW:VC26:EnableBi	binary input	1867	ENABLE/DISABLE
G:PW:VC26:PumpStatBi	binary input	1868	ON/OFF
G:PW:VC26B:PumpStatBi	binary input	1869	ON/OFF
G:PW:VC26:LoLoAlarmBi	binary input	1870	NORMAL/ALARM
G:PW:VC26:LoLvAlarmBi	binary input	1871	NORMAL/ALARM
G:PW:VC26:FloSwStatBi	binary input	1872	FLOW/NOFLOW

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**VACUUM CHAMBER COOLING SYSTEM****SECTORS 27 AND 28 LOCATED IN BLDG. 400 MEZZANINE COLUMN 138****Table 35: APS\Net_Port\Bldg_400\Proc_Wtr\NPSRVC13**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:VC28:SupTempAi	analog input	625	Deg. F.
G:PW:VC28:EnableBi	binary input	1873	ENABLE/DISABLE
G:PW:VC28:PumpStatBi	binary input	1874	ON/OFF
G:PW:VC28B:PumpStatBi	binary input	1875	ON/OFF
G:PW:VC28:LoLoAlarmBi	binary input	1876	NORMAL/ALARM
G:PW:VC28:LoLvAlarmBi	binary input	1877	NORMAL/ALARM
G:PW:VC28:FloSwStatBi	binary input	1878	FLOW/NOFLOW

SECTORS 29 AND 30 LOCATED IN BLDG. 400 MEZZANINE COLUMN 144**Table 36: APS\Net_Port\Bldg_400\Proc_Wtr\NPSRVC14**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:VC30:SupTempAi	analog input	627	Deg. F.
G:PW:VC30:EnableBi	binary input	1879	ENABLE/DISABLE
G:PW:VC30:PumpStatBi	binary input	1880	ON/OFF
G:PW:VC30B:PumpStatBi	binary input	1881	ON/OFF
G:PW:VC30:LoLoAlarmBi	binary input	1882	NORMAL/ALARM
G:PW:VC30:LoLvAlarmBi	binary input	1883	NORMAL/ALARM
G:PW:VC30:FloSwStatBi	binary input	1884	FLOW/NOFLOW

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**VACUUM CHAMBER COOLING SYSTEM****SECTORS 31 AND 32 LOCATED IN BLDG. 400 MEZZANINE COLUMN 150****Table 37: APS\Net_Port\Bldg_400\Proc_Wtr\NPSRVC15**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:VC32:SupTempAi	analog input	629	Deg. F.
G:PW:VC32:EnableBi	binary input	1885	ENABLE/DISABLE
G:PW:VC32:PumpStatBi	binary input	1886	ON/OFF
G:PW:VC32B:PumpStatBi	binary input	1887	ON/OFF
G:PW:VC32:LoLoAlarmBi	binary input	1888	NORMAL/ALARM
G:PW:VC32:LoLvAlarmBi	binary input	1889	NORMAL/ALARM
G:PW:VC32:FloSwStatBi	binary input	1890	FLOW/NOFLOW

SECTORS 33 AND 34 LOCATED IN BLDG. 400 MEZZANINE COLUMN 156**Table 38: APS\Net_Port\Bldg_400\Proc_Wtr\NPSRVC16**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:VC34:SupTempAi	analog input	631	Deg. F.
G:PW:VC34:EnableBi	binary input	1891	ENABLE/DISABLE
G:PW:VC34:PumpStatBi	binary input	1892	ON/OFF
G:PW:VC34B:PumpStatBi	binary input	1893	ON/OFF
G:PW:VC34:LoLoAlarmBi	binary input	1894	NORMAL/ALARM
G:PW:VC34:LoLvAlarmBi	binary input	1895	NORMAL/ALARM
G:PW:VC34:FloSwStatBi	binary input	1896	FLOW/NOFLOW

PROCESS WATER FLOW FOR BUILDING 400 (STORAGE RING)**VACUUM CHAMBER COOLING SYSTEM****SECTORS 35 AND 36 LOCATED IN BLDG. 400 MEZZANINE COLUMN 162****Table 39: APS\Net_Port\Bldg_400\Proc_Wtr\NPSRVC17**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:VC36:SupTempAi	analog input	633	Deg. F.
G:PW:VC36:EnableBi	binary input	1897	ENABLE/DISABLE
G:PW:VC36:PumpStatBi	binary input	1898	ON/OFF
G:PW:VC36B:PumpStatBi	binary input	1899	ON/OFF
G:PW:VC36:LoLoAlarmBi	binary input	1900	NORMAL/ALARM
G:PW:VC36:LoLvAlarmBi	binary input	1901	NORMAL/ALARM
G:PW:VC36:FloSwStatBi	binary input	1902	FLOW/NOFLOW

SECTORS 37 AND 38 LOCATED IN BLDG. 400 MEZZANINE COLUMN 168**Table 40: APS\Net_Port\Bldg_400\Proc_Wtr\NPSRVC18**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:VC38:SupTempAi	analog input	635	Deg. F.
G:PW:VC38:EnableBi	binary input	1903	ENABLE/DISABLE
G:PW:VC38:PumpStatBi	binary input	1904	ON/OFF
G:PW:VC38B:PumpStatBi	binary input	1905	ON/OFF
G:PW:VC38:LoLoAlarmBi	binary input	1906	NORMAL/ALARM
G:PW:VC38:LoLvAlarmBi	binary input	1907	NORMAL/ALARM
G:PW:VC38:FloSwStatBi	binary input	1908	FLOW/NOFLOW

PROCESS WATER FLOW FOR BUILDING 411/412 (LINAC/PAR/BOOSTER)**SECONDARY LOOP****PUMPS LOCATED IN BLDG. 412 GALLERY AREA ABOVE PAR ENCLOSURE**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:PRKLY:SupTempAi	analog input	51	Deg. F.
G:PW:PRKLY:SetPtAi	analog input	52	Deg. F.
G:PW:PRKLY:DiffPresAi	analog input	53	PSIG
G:PW:PRKLY:DiffPresSetPtAi	analog input	54	PSIG
G:PW:PRKLY:SupFloAi	analog input	55	GPM
G:PW:PRKLY:RetFloAi	analog input	56	GPM
G:PW:PRKLY:MixValAi	analog input	57	% CLG
G:PW:PRKLY:ByPassValAi	analog input	58	% CLOS
G:PW:PRKLY:EnabBi	binary input	901	ENABLE/DISABLE
G:PW:PRKLY:HiFloEvBi	binary input	902	ON/OFF
G:PW:PRKLY:StatusBi	binary input	903	ON/OFF
G:PW:PRKLY:AlarmBi	binary input	904	NORMAL/ALARM
G:PW:PRKLY:IsoValStatBi	binary input	905	OPEN/CLOSED
G:PW:PRKLY:SuStbyValStatBi	binary input	906	OPEN/CLOSED
G:PW:PRKLY:RtStbyValStatBi	binary input	907	OPEN/CLOSED

Table 41:**APS\Net_Port\Bldg_411\Proc_Wtr\NP_GAL**

PROCESS WATER FLOW FOR BUILDING 411/412 (LINAC/PAR/BOOSTER)**SECONDARY LOOP****PUMPS LOCATED IN BLDG. 412 GALLERY AREA ABOVE PAR ENCLOSURE**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:PR-LT:SupTempAi	analog input	59	Deg. F.
G:PW:PR-LT:SetPtAi	analog input	60	Deg. F.
G:PW:PR-LT:DiffPresAi	analog input	61	PSIG
G:PW:PR-LT:DiffPresSetPtAi	analog input	62	PSIG
G:PW:PR-LT:SupFloAi	analog input	63	GPM
G:PW:PR-LT:RetFloAi	analog input	64	GPM
G:PW:PR-LT:MixValAi	analog input	65	% CLG
G:PW:PR-LT:ByPassValAi	analog input	66	% CLOS
G:PW:PR-LT:EnabBi	binary input	909	ENABLE/DISABLE
G:PW:PR-LT:HiFloEvBi	binary input	910	ON/OFF
G:PW:PR-LT:StatusBi	binary input	911	ON/OFF
G:PW:PR-LT:AlarmBi	binary input	912	NORMAL/ALARM
G:PW:PR-LT:IsoValStatBi	binary input	913	OPEN/CLOSED
G:PW:PR-LT:SuStbyValStatBi	binary input	914	OPEN/CLOSED
G:PW:PR-LT:RtStbyValStatBi	binary input	915	OPEN/CLOSED

Table 42:**APS\Net_Port\Bldg_411\Proc_Wtr\NP_TUN**

PROCESS WATER FLOW FOR BUILDING 411 (LINAC/PAR/BOOSTER)**SECONDARY LOOP****PUMPS LOCATED IN BLDG. 412 GALLERY AREA ABOVE PAR**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:PRPAR:SupTempAi	analog input	67	Deg. F.
G:PW:PRPAR:SetPtAi	analog input	68	Deg. F.
G:PW:PRPAR:DiffPresAi	analog input	69	PSIG
G:PW:PRPAR:DiffPresSetPtAi	analog input	70	PSIG
G:PW:PRPAR:SupFloAi	analog input	71	GPM
G:PW:PRPAR:RetFloAi	analog input	72	GPM
G:PW:PRPAR:MixValAi	analog input	73	% CLG
G:PW:PRPAR:ByPassValAi	analog input	74	% CLOS
G:PW:PRPAR:EnabBi	binary input	917	ENABLE/DISABLE
G:PW:PRPAR:HiFloEvBi	binary input	918	ON/OFF
G:PW:PRPAR:StatusBi	binary input	919	ON/OFF
G:PW:PRPAR:AlarmBi	binary input	920	NORMAL/ALARM
G:PW:PRPAR:IsoValStatBi	binary input	921	OPEN/CLOSED
G:PW:PRPAR:SuStbyValStatBi	binary input	922	OPEN/CLOSED
G:PW:PRPAR:RtStbyValStatBi	binary input	923	OPEN/CLOSED

Table 43:**APS\Net_Port\Bldg_411\Proc_Wtr\NP_INJW**

PROCESS WATER FLOW FOR BUILDING 411 (LINAC/PAR/BOOSTER)**SECONDARY LOOP****PUMPS LOCATED IN BLDG. 412 GALLERY AREA ABOVE ROOM B102**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:IWSYA:SupTempAi	analog input	75	Deg. F.
G:PW:IWSYA:SetPtAi	analog input	76	Deg. F.
G:PW:IWSYA:DiffPresAi	analog input	77	PSIG
G:PW:IWSYA:DiffPresSetPtAi	analog input	78	PSIG
G:PW:IWSYA:SupFloAi	analog input	79	GPM
G:PW:IWSYA:RetFloAi	analog input	80	GPM
G:PW:IWSYA:MixValAi	analog input	81	% CLG
G:PW:IWSYA:ByPassValAi	analog input	82	% CLOS
G:PW:IWSYA:EnabBi	binary input	925	ENABLE/DISABLE
G:PW:IWSYA:HiFloEvBi	binary input	926	ON/OFF
G:PW:IWSYA:StatusBi	binary input	927	ON/OFF
G:PW:IWSYB:StatusBi	binary input	928	ON/OFF
G:PW:IWSYA:AlarmBi	binary input	929	NORMAL/ALARM
G:PW:IWSYA:IsoValStatBi	binary input	930	OPEN/CLOSED
G:PW:PR-SB:StatusBi	binary input	932	ON/OFF

Table 44:**APS\Net_Port\Bldg_411\Proc_Wtr\NP_STS**

PROCESS WATER FLOW FOR BUILDING 411/412 (LINAC/PAR/BOOSTER)**LINAC LT-5 WATER SKID LOCATED IN LINAC GALLERY**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:LIWS:LT5-HtrTempAi	analog	137	Deg. F.
G:LIWS:LT5-HtrStPtAi	analog	138	Deg. F.
G:LIWS:LT5-PWTempAi	analog	139	Deg. F.
G:LIWS:LT5-HtrNorTempRanBi	binary	953	HTG/OFF

Table 45: **APS\Net_Port\Bldg_411\Proc_Wtr\NP_LT-5****BUILDING 411/412 AIR TEMPERATURES (LINAC/PAR/BOOSTER)**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:IAHU:KlyZnTempAi	analog	130	Deg. F.
G:IAHU:LiTunlEastTempAi	analog	131	Deg. F.
G:IAHU:LiTunlWestTempAi	analog	132	Deg. F.
G:IAHU:SynTunlSouthTempAi	analog	133	Deg. F.

Table 46: **APS\Net_Port\Bldg_411\AHUs\NP_411AH**

PROCESS WATER FLOW FOR BUILDING 420 (RF/EXTRACTION WING)**SECONDARY LOOP****PUMPS LOCATED ON SOUTH MEZZANINE**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:RF-SY:SupTempAi	analog input	217	Deg. F.
G:PW:RF-SY:DiffPresAi	analog input	219	PSIG
G:PW:RF-SY:DiffPresSetPtAi	analog input	220	PSIG
G:PW:RF-SY:SupFloAi	analog input	221	GPM
G:PW:RF-SY:RetFloAi	analog input	222	GPM
G:PW:RF-SY:ByPassValAi	analog input	224	% CLOS
G:PW:RF-SY:EnabBi	binary input	1217	ENABLE/DISABLE
G:PW:RF-SY:HiFloEvBi	binary input	1218	ON/OFF
G:PW:RF-SY:StatusBi	binary input	1219	ON/OFF
G:PW:RF-SY:AlarmBi	binary input	1220	NORMAL/ALARM
G:PW:RF-SY:IsoValStatBi	binary input	1221	OPEN/CLOSED
G:PW:RF-SY:SuStbyValStatBi	binary input	1222	OPEN/CLOSED
G:PW:RF-SY:RtStbyValStatBi	binary input	1223	OPEN/CLOSED

Table 47:

PUMPS LOCATED ON SOUTH MEZZANINE

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:RF-1:SupTempAi	analog input	201	Deg. F.
G:PW:RF-1:DiffPresAi	analog input	203	PSIG
G:PW:RF-1:DiffPresSetPtAi	analog input	204	PSIG
G:PW:RF-1:SupFloAi	analog input	205	GPM
G:PW:RF-1:RetFloAi	analog input	206	GPM
G:PW:RF-1:ByPassValAi	analog input	208	% CLOS
G:PW:RF-1:EnabBi	binary input	1201	ENABLE/DISABLE
G:PW:RF-1:HiFloEvBi	binary input	1202	ON/OFF
G:PW:RF-1:StatusBi	binary input	1203	ON/OFF
G:PW:RF-1:AlarmBi	binary input	1204	NORMAL/ALARM
G:PW:RF-1:IsoValStatBi	binary input	1205	OPEN/CLOSED
G:PW:RF-1:SuStbyValStatBi	binary input	1206	OPEN/CLOSED
G:PW:RF-1:RtStbyValStatBi	binary input	1207	OPEN/CLOSED

Table 48: **APS\Net_Port\Bldg_420\Proc_Wtr\NP_RF1**

PROCESS WATER FLOW FOR BUILDING 420 (RF/EXTRACTION WING)**SECONDARY LOOP****PUMPS LOCATED ON SOUTH MEZZANINE**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:RF-2:SupTempAi	analog input	209	Deg. F.
G:PW:RF-2:DiffPresAi	analog input	211	PSIG
G:PW:RF-2:DfPresSetPtAi	analog input	212	PSIG
G:PW:RF-2:SupFloAi	analog input	213	GPM
G:PW:RF-2:RetFloAi	analog input	214	GPM
G:PW:RF-2:ByPassValAi	analog input	216	% CLOS
G:PW:RF-2:EnabBi	binary input	1209	ENABLE/DISABLE
G:PW:RF-2:HiFloEvBi	binary input	1210	ON/OFF
G:PW:RF-2:StatusBi	binary input	1211	ON/OFF
G:PW:RF-2:AlarmBi	binary input	1212	NORMAL/ALARM
G:PW:RF-2:IsoValStatBi	binary input	1213	OPEN/CLOSED
G:PW:RF-2:SuStbyValStBi	binary input	1214	OPEN/CLOSED
G:PW:RF-2:RtStbyValStBi	binary input	1215	OPEN/CLOSED

Table 49:**APS\Net_Port\Bldg_420\Proc_Wtr\NP_RF2**

PROCESS WATER FLOW FOR BUILDING 420 (RF/EXTRACTION WING)**SECONDARY LOOP****PUMPS LOCATED ON SOUTH MEZZANINE**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:RF-3:SupTempAi	analog input	236	Deg. F.
G:PW:RF-3:DiffPresAi	analog input	238	PSIG
G:PW:RF-3:DiffPresSetPtAi	analog input	239	PSIG
G:PW:RF-3:SupFloAi	analog input	240	GPM
G:PW:RF-3:RetFloAi	analog input	241	GPM
G:PW:RF-3:ByPassValAi	analog input	243	% CLOS
G:PW:RF-3:EnabBi	binary input	1234	ENABLE/DISABLE
G:PW:RF-3:HiFloEvBi	binary input	1235	ON/OFF
G:PW:RF-3:StatusBi	binary input	1236	ON/OFF
G:PW:RF-3:AlarmBi	binary input	1237	NORMAL/ALARM
G:PW:RF-3:IsoValStatBi	binary input	1238	OPEN/CLOSED
G:PW:RF-3:SuStbyValStatBi	binary input	1239	OPEN/CLOSED
G:PW:RF-3:RtStbyValStatBi	binary input	1240	OPEN/CLOSED

Table 50:**APS\Net_Port\Bldg_420\Proc_Wtr\NP_RF3**

PROCESS WATER FLOW FOR BUILDING 420 (RF/EXTRACTION WING)**SECONDARY LOOP****PUMPS LOCATED ON SOUTH MEZZANINE**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:RF-5:SupTempAi	analog input	252	Deg. F.
G:PW:RF-5:DiffPresAi	analog input	254	PSIG
G:PW:RF-5:DiffPresSetPtAi	analog input	255	PSIG
G:PW:RF-5:SupFloAi	analog input	256	GPM
G:PW:RF-5:RetFloAi	analog input	257	GPM
G:PW:RF-5:ByPassValAi	analog input	259	% CLOS
G:PW:RF-5:EnabBi	binary input	1250	ENABLE/DISABLE
G:PW:RF-5:HiFloEvBi	binary input	1251	ON/OFF
G:PW:RF-5:StatusBi	binary input	1252	ON/OFF
G:PW:RF-5:AlarmBi	binary input	1253	NORMAL/ALARM
G:PW:RF-5:IsoValStatBi	binary input	1254	OPEN/CLOSED
G:PW:RF-5:SuStbyValStatBi	binary input	1255	OPEN/CLOSED
G:PW:RF-5:RtStbyValStatBi	binary input	1256	OPEN/CLOSED

Table 51:**APS\Net_Port\Bldg_420\Proc_Wtr\NP_RF5**

PROCESS WATER FLOW FOR BUILDING 420 (RF/EXTRACTION WING)**SECONDARY LOOP****PUMPS LOCATED ON SOUTH MEZZANINE**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:RF-4:SupTempAi	analog input	244	Deg. F.
G:PW:RF-4:DiffPresAi	analog input	246	PSIG
G:PW:RF-4:DiffPresSetPtAi	analog input	247	PSIG
G:PW:RF-4:SupFloAi	analog input	248	GPM
G:PW:RF-4:RetFloAi	analog input	249	GPM
G:PW:RF-4:ByPassValAi	analog input	251	% CLOS
G:PW:RF-4:EnabBi	binary input	1242	ENABLE/DISABLE
G:PW:RF-4:HiFloEvBi	binary input	1243	ON/OFF
G:PW:RF-4:StatusBi	binary input	1244	ON/OFF
G:PW:RF-4:AlarmBi	binary input	1245	NORMAL/ALARM
G:PW:RF-4:IsoValStatBi	binary input	1246	OPEN/CLOSED
G:PW:RF-4:SuStbyValStatBi	binary input	1247	OPEN/CLOSED
G:PW:RF-4:RtStbyValStatBi	binary input	1248	OPEN/CLOSED

Table 52:**APS\Net_Port\Bldg_420\Proc_Wtr\NP_RF4**

PROCESS WATER FLOW FOR BUILDING 420 (RF/EXTRACTION WING)**SECONDARY LOOP****PUMPS LOCATED ON SOUTH MEZZANINE**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:PW:RFLDA:SupTempAi	analog input	225	Deg. F.
G:PW:RFLDA:DiffPresAi	analog input	227	PSIG
G:PW:RFLDA:DiffPresSetPtAi	analog input	228	PSIG
G:PW:RFLDA:SupFloAi	analog input	229	GPM
G:PW:RFLDA:RetFloAi	analog input	230	GPM
G:PW:RFLDA:ByPassValAi	analog input	232	% CLOS
G:PW:RFLDA:EnabBi	binary input	1225	ENABLE/DISABLE
G:PW:RFLDA:HiFloEvBi	binary input	1226	ON/OFF
G:PW:RFLDA:StatusBi	binary input	1227	ON/OFF
G:PW:RFLDB:StatusBi	binary input	1228	ON/OFF
G:PW:RFLDA:AlarmBi	binary input	1229	NORMAL/ALARM
G:PW:RFLDA:IsoValStatBi	binary input	1230	OPEN/CLOSED
G:PW:RFSBE:StatusBi	binary input	1232	ON/OFF
G:PW:RFSBW:StatusBi	binary input	1233	ON/OFF

Table 53:**APS\Net_Port\Bldg_420\Proc_Wtr\NP_908-9**

BUILDING 420 AIR TEMPERATURES (SYNC. TUNNEL NORTH/EXT ZONE)

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:SAHU:SynTunlNorthTempAi	analog	260	Deg. F.
G:SAHU:RFExtZnTempAi	analog	261	Deg. F.

Table 54: **APS\Net_Port\Bldg_420\AHUs\NP_420AH****BUILDING 450 MAIN PUMPING STATION****PRIMARY LOOP**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:DIWP:OutAirTempAi	analog input	1	Deg. F.
G:DIWP:OutAirHumAi	analog input	2	% Rel. H..
G:DIWS:PWSupTempAi	analog input	3	Deg. F.
G:DIWS:PWRetTempAi	analog input	4	Deg. F.
G:DIWP:PWDISysPresAi	analog input	5	psig
G:DIWP:PWDIPresPreviousAi	analog input	6	psig
G:DIWP:PWPresRateChangeAi	analog input	7	psig/m
G:DIWP:PW10-SampAveAi	analog input	8	psig/m
G:DIWP:PW20-SampAveAi	analog input	9	psig/m
G:DIWP:PW30-SampAveAi	analog input	10	psig/m
G:DIWP:PWMakeupResAi	analog input	11	MegOhm
G:DIWP:PWStorTankResAI	analog input	12	MegOhm

Table 55: **APS\Net_Port\Bldg\450\NP_450**

PROCESS VARIABLE NAME AND INFORMATION			
PROCESS VARIABLE NAME	INPUT	ITEM	UNITS
G:DIWP:PW815StatusBi	binary input	800	ON/OFF
G:DIWP:PW816StatusBi	binary input	801	ON/OFF
G:DIWP:PW817StatusBi	binary input	802	ON/OFF
G:DIWP:GeneratorStatusBi	binary input	803	ON/OFF

Table 55:**APS\Net_Port\Bldg\450\NP_450**